



**Nebraska UST Operator Inspection Checklist
 Annual Walkthrough Inspection**

Annual walkthrough inspections must be kept at least three years after the last inspection date on the form.

This inspection is to be completed by a person with knowledge of the UST system. (Examples: owner or operator, trained A/B Operator, service technician). Annual walkthrough inspections must be conducted at least once a year. Records must include a list of each area checked, whether each area checked was acceptable or needed action taken, a description of actions taken to correct an issue. If problems are found during the walkthrough inspection, the person conducting the inspection must take action quickly to resolve these problems and avoid serious releases.

Facility Name: _____ SFM Facility ID: _____
 Site Address: _____
 City, County: _____ Zip Code: _____

Required Activities (TITLE 159 CH 6.007 AND CFR 280.36)

Containment Sumps	Date	Initials	Checked
Visually check each containment sump for damage; are the containments free of bulges, holes, cracks?			<input type="checkbox"/>
Visually check for leaks to the containment area or releases to the environment			<input type="checkbox"/>
Verify containments are free of liquid or debris; remove any liquid or debris if found			<input type="checkbox"/>
For double walled sumps with interstitial monitoring, check for leaks in the interstitial area (If not applicable check N/A)			<input type="checkbox"/>
Handheld Release Detection Equipment		Initials	Checked
Check handheld release detection equipment, such as tank gauge sticks or groundwater bailers for operability and serviceability. Verify gauge stick measurements are visible to an 1/8 inch.			<input type="checkbox"/>

Are there any items from the walkthrough that require corrective actions be completed? Yes No

UST System Maintenance/Repair Record		
Identify Problem/Defective UST System Component	Date of Repair	Who Did Repair?

Name of individual performing walkthrough inspection:

Name (Print):
Signature: Date: