

CHAPTER 7 RELEASE DETECTION REQUIREMENTS

001. GENERAL REQUIREMENTS FOR ALL UST SYSTEMS

The requirements of 40 CFR 280.40 as it existed on July 15, 2015 are adopted and incorporated and by reference.

001.01 UST systems larger than 1,100 gallons used to store heating oil are excluded for purposes of all release detection on tanks required in this chapter except that they must perform the manual tank gauging procedures in 40 CFR 280.43(b) on a monthly basis from April 1 to November 1.

002. REQUIREMENTS FOR PETROLEUM UST SYSTEMS

The requirements of 40 CFR 280.41 as it existed on July 15, 2015 are adopted and incorporated by reference.

003. REQUIREMENTS FOR HAZARDOUS SUBSTANCE UST SYSTEMS

The requirements of 40 CFR 280.42 as it existed on July 15, 2015, are adopted and incorporated by reference.

004. METHODS OF RELEASE DETECTION FOR TANKS

The requirements of 40 CFR 280.43 as it existed on July 15, 2015 are adopted and incorporated by reference.

Owners and operators will conduct and record the daily product inventory control requirements as described in 40 CFR 280.43 (a)(1)-(a)(6) for all new and existing UST systems.

[Exception: UST systems eligible for and utilizing manual tank gauging in accordance with 40 CFR 280.43(b), do not need to meet the daily inventory requirement.]

005. METHODS OF RELEASE DETECTION FOR PIPING

The requirements of 40 CFR 280.44 as it existed on July 15, 2015 are adopted and incorporated by reference.

006. RELEASE DETECTION RECORD KEEPING

The requirements of 40 CFR 280.45 as it existed on July 15, 2015 are adopted and incorporated by reference.

