

## Title 153 - STATE FIRE MARSHAL

### Chapter 17 - NEW TANK INSTALLATION PERMIT AND FEE REQUIREMENTS ABOVEGROUND STORAGE TANKS STORING CLASS I AND CLASS II FLAMMABLE LIQUIDS

#### 001. Tank Installation Permit.

001.01. Owners/operators shall obtain an installation permit for all new and replacement tank and piping installations.

001.01A. Applications for installation permits shall be provided by and filed with the State Fire Marshal's office. Submission of a detailed site plan and a \$50.00 inspection fee must be made at least ten (10) working days prior to the proposed installation. The \$50.00 fee is per installation, regardless of the number of tanks involved.

001.01B. Tank installations shall meet all the applicable criteria set out in the NFPA codes promulgated by the State Fire Marshal.

001.01C. Notification of date and time of installation shall be given to the State Fire Marshal Flammable Liquids Division at least 24 hours prior to installation.

#### 002. Permit Denial and Revocation.

Persons whose application for a permit is denied or revoked shall have the right to request a hearing under procedures established by the State Fire Marshal. When the State Fire Marshal has reason to believe that a permit holder's activities create an immediate threat to public safety, a permit may be suspended until the hearing process is complete. Any person aggrieved by a final decision of the State Fire Marshal may appeal such action pursuant to State Statutes 84-917 to 84-919, N.R.S.

Legal Citation: Title 153, Ch. 17, Nebraska State Fire Marshal